Polygon-Connected Autotransformer Based 28-Pulse AC-DC Converter for Power Quality Improvement

R. Abdollahi, and A. Jalilian

***Abstract*-- This paper presents the design and analysis of a Polygon-Connected autotransformer based 28-pulse ac-dc converter which supplies direct torque controlled induction motor drives (DTCIMD's) in order to have better power quality conditions at the point of common coupling. The proposed converter output voltage is accomplished via two paralleled 14-pulse ac-dc converters. An autotransformer is designed to supply the rectifiers. The design procedure of magnetics is in a way such that makes it suitable for retrofit applications where a six-pulse diode bridge rectifier is being utilized. The aforementioned structure improves power quality criteria at ac mains and makes them consistent with the IEEE-519 standard requirements for varying loads. Furthermore, near unity power factor is obtained for a wide range of DTCIMD operation. A comparison is made between 6-pulse and proposed converters from view point of power quality indices. Results show that input current total harmonic distortion (THD) is less than 5% for the proposed topology at variable loads.**

***Index Terms*--AC–DC Converter, Polygon-Connected Autotransformer, Power Quality, 28 pulse, Direct Torque Controlled Motor Drives (DTCIMD's).**

I. Introduction

Recent advances in solid state conversion technology has led to the proliferation of variable frequency induction motor drives (VFIMD's) that are used in several applications such as air conditioning, blowers, fans, pumps for waste water treatment plants, textile mills, rolling mills etc [1]. The most practical technique in VFIMD's is vector-controlled strategy in that it offers better performance rather than the other control techniques. Vector-controlled technique is implemented in voltage source inverter which is mostly fed from six-pulse diode bridge rectifier, Insulated gate bipolar transistors (IGBT's) are employed as the VSI switches.

The most important drawback of the six-pulse diode-bridge rectifier is its poor power factor injection of current harmonics into ac mains. The circulation of current harmonics into the source impedance yields in harmonic polluted voltages at the point of common coupling (PCC) and consequently resulting in undesired supply voltage conditions for costumers in the vicinity. The value of current harmonic components which are injected into the grid by nonlinear loads such as DTCIMD's should be confined within the standard limitations. The most prominent standards in this field are IEEE standard 519 [2] and the International Electrotechnical Commission (IEC) 61000-3-2 [3].

According to considerable growth of Static Power Converters (SPC's) that are the major sources of harmonic distortion and as a result their power quality problems, researchers have focused their attention on harmonic eliminating solutions. For DTCIMD's one effective solution is to employ multipulse AC-DC converters. These converters are based on either phase multiplication or phase shifting or pulse doubling or a combination [4]-[8].

Although, in the conditions of light load or small source impedance, line current total harmonic distortion (THD) will be more than 5% for up to 18-pulse AC-DC converters [9]-[15]. A Polygon-Connected Autotransformer-Based 24-pulse AC-DC converter is reported in [18] which has THD variation of 4.48% to 5.65% from full-load to light-load (20% of full-load). Another T-Connected Autotransformer-Based 24-Pulse AC–DC Converter has also been presented in [21], however, the THD of the supply current with this topology is reported to vary from 2.46% to 5.20% which is more than 5% when operating at light load.

In this paper, a 28-pulse ac-dc converter is proposed employing a novel Polygon-Connected autotransformer. The proposed design method will be suitable even when the transformer output voltages vary while keeping its 28-pulse operation.

R. Abdollahi is Msc student at the Department of Electrical Engineering, Iran University of Science and Technology, Tehran, Iran

A. Jalilian is with the Department of Electrical Engineering, Centre of Excellence for Power System Automation and Operation, Iran University of Science and Technology, Tehran, Iran.



Fig. 1. Polygon-Connected -autotransformer configuration for 28-pulse ac–dc conversion.

In the proposed structure, two 7-leg diode-bridge rectifiers are paralleled via two interphase transformers and fed from an autotransformer. Hence, a 28-pulse output voltage is obtained. Detailed design tips of the IPT and totally the whole structure of 28-pulse ac-dc converter are described in this paper and the proposed converter is modeled and simulated in MATLAB to study its behavior and specifically to analyze the power quality indices at ac mains.

Furthermore, a 28-pulse ac-dc converter consisting of a Polygon-Connected autotransformer, two 14-pulse diode bridge rectifiers paralleled through two IPTs, and with a DTCIMD load Fig. 1. Simulation results of six-pulse and proposed 28-pulse ac-dc converters feeding a DTCIMD load are scheduled and various quality criteria such as THD of ac mains current, power factor, displacement factor, distortion factor, and THD of the supply voltage at PCC are compared.

II. PROPOSED 28-PULSE AC–DC CONVERTER

In order to implement a 28-pulse ac-dc converter through paralleling two bridge rectifiers, i.e. two 14-pulse rectifiers, two sets of 7-phase voltages with a phase difference of 51.43 degrees between the voltages of each group and 12.86 degrees between the same voltages of the two groups are required. Accordingly, each bridge rectifier consists of 7 common-anode and 7 common-cathode diodes (two 7-leg rectifiers). Autotransformer connections and its phasor diagram which shows the angular displacement of voltages are illustrated in Fig. 2.

A. Design of Proposed Autotransformer for 28-Pulse AC–DC Converter

The aforementioned two voltage sets are called as (V_{a1}, V_{a2}, V_{a3}, V_{a4}, V_{a5}, V_{a6}, V_{a7}) and (V_{b1}, V_{b2}, V_{b3}, V_{b4}, V_{b5}, V_{b6}, V_{b7}) that are fed to rectifiers I and II, respectively. The same voltages of the two groups, i.e. V_{ai} and V_{bi}, are phase displaced of 12.86 degrees. V_{a1} and V_{b1} has a phase shift of +6.34 and -6.34 degrees from the input voltage of phase A, respectively. According to phasor diagram, the seven-phase voltages are made from ac main phase and line voltages with fractions of the primary winding turns which are expressed with the following relationships. Consider three-phase voltages of primary windings as follows:

$$V_A = V_s\angle 0^\circ,\ V_B = V_s\angle -120^\circ,\ V_C = V_s\angle 120^\circ. \tag{1}$$

Where, seven-phase voltages are:

$$\begin{aligned} &V_{a1} = V_s\angle 6.43^\circ, V_{a2} = V_s\angle -45^\circ,\\ &V_{a3} = V_s\angle -96.43^\circ, V_{a4} = V_s\angle -147.86^\circ,\\ &V_{a5} = V_s\angle -199.28^\circ, V_{a6} = V_s\angle -250.71^\circ,\\ &V_{a7} = V_s\angle -302.14^\circ \end{aligned} \tag{2}$$

$$\begin{aligned} &V_{b1} = V_s\angle -6.43^\circ, V_{b2} = V_s\angle -57.86^\circ,\\ &V_{b3} = V_s\angle -109.29^\circ, V_{b4} = V_s\angle -160.71^\circ,\\ &V_{b5} = V_s\angle -212.14^\circ, V_{b6} = V_s\angle -263.57^\circ,\\ &V_{b7} = V_s\angle -315^\circ \end{aligned} \tag{3}$$

Input voltages for converter I are:

$$\begin{aligned} &V_{a1} = V_a + K_1V_{CA} - K_2V_{BC}\\ &V_{a2} = V_{b1} - K_3V_{AB} + K_4V_{BC}\\ &V_{a3} = V_{b3} - K_8V_{AB} - K_7V_{CA}\\ &V_{a4} = V_b - K_{11}V_{BC} + K_{12}V_{CA}\\ &V_{a5} = V_{b5} + K_{13}V_{BC} - K_{14}V_{AB}\\ &V_{a6} = V_C - K_{10}V_{CA} + K_9V_{AB}\\ &V_{a7} = V_{b7} + K_5V_{CA} - K_6V_{BC} \end{aligned} \tag{4}$$

Input voltages for converter II are:

$$\begin{aligned} &V_{b1} = V_a - K_1V_{AB} + K_2V_{BC}\\ &V_{b2} = V_{a2} - K_5V_{AB} + K_6V_{BC}\\ &V_{b3} = V_b + K_{10}V_{AB} - K_9V_{CA}\\ &V_{b4} = V_{a4} - K_{13}V_{BC} + K_{14}V_{CA}\\ &V_{b5} = V_c + K_{11}V_{BC} - K_{12}V_{AB}\\ &V_{b6} = V_{a6} - K_8V_{CA} + K_7V_{AB}\\ &V_{b7} = V_{a1} + K_3V_{CA} - K_4V_{BC} \end{aligned} \tag{5}$$

$$V_{AB} = \sqrt{3}V_A\angle 30^\circ, V_{BC} = \sqrt{3}V_B\angle 30^\circ, V_{CA} = \sqrt{3}V_C\angle 30^\circ. \tag{6}$$

Constants K_1-K_{14} are calculated using (2)-(6) to obtain the required windings turn numbers to have the desired phase shift for the two voltage sets:

$$\begin{aligned} &K_1 = 0.0042, K_2 = 0.0625, K_3 = 0.1910\\ &K_4 = 0.2481, K_5 = 0.1168, K_6 = 0.0222\\ &K_7 = 0.1297, K_8 = 0.2995, K_9 = 0.1016\\ &K_{10} = 0.0439, K_{11} = 0.1014, K_{12} = 0.0116\\ &K_{13} = 0.0773, K_{14} = 0.2311. \end{aligned} \tag{7}$$

B. Design of Autotransformer for Retrofit Applications

The value of output voltage in multipulse rectifiers boosts relative to the output voltage of a six-pulse converter making the multipulse rectifier inappropriate for retrofit applications. For instance, with the autotransformer arrangement of the proposed 28-pulse converter, the rectified output voltage is 18% higher than that of six-pulse rectifier.

For retrofit applications, the above design procedure is modified so that the dc-link voltage becomes equal to that of six-pulse rectifier. This will be accomplished via modifications in the tapping positions on the windings as shown in Fig. 3.



Fig.2. Polygon- connection of proposed autotransformer for 28-pulse converter and its phasor representation.

It should be noted that with this approach, the desired phase shift is still unchanged. Similar to section II part A, the following equations can be derived as:

$$|V_S| = 0.842\,|V_A| \tag{8}$$

Input voltages for converter I are:

$$\begin{aligned}
V_{a1} &= V_a + K_1 V_{CA} \\
V_{a2} &= V_{b1} - K_2 V_{AB} + K_3 V_{BC} \\
V_{a3} &= V_{b3} + K_7 V_{AB} - K_6 V_{CA} \\
V_{a4} &= V_b - K_{10} V_{BC} + K_{11} V_{CA} \\
V_{a5} &= V_{b5} + K_{12} V_{BC} - K_{13} V_{AB} \\
V_{a6} &= V_c - K_9 V_{CA} + K_8 V_{AB} \\
V_{a7} &= V_{b7} + K_4 V_{CA} - K_5 V_{BC}
\end{aligned} \tag{9}$$

Input voltages for converter II are:

$$\begin{aligned}
V_{b1} &= V_a - K_1 V_{CA} \\
V_{b2} &= V_{a2} - K_4 V_{AB} + K_5 V_{BC} \\
V_{b3} &= V_b + K_9 V_{AB} - K_8 V_{CA} \\
V_{b4} &= V_{a4} - K_{12} V_{BC} + K_{13} V_{CA} \\
V_{b5} &= V_C + K_{10} V_{BC} - K_{11} V_{AB} \\
V_{b6} &= V_{a6} - K_7 V_{CA} + K_6 V_{AB} \\
V_{b7} &= V_{a1} + K_2 V_{CA} - K_3 V_{BC}
\end{aligned} \tag{10}$$

Accordingly, the values of constants K_1-K_{14} are changed for retrofit applications as:



Fig.3. Phasor diagram of voltages in the proposed autotransformer connection alongwith modifications for retrofit arrangement.

$$\begin{aligned}
&K_1 = 0.1089, K_2 = 0.1609, K_3 = 0.2088 \\
&K_4 = 0.0983, K_5 = 0.0186, K_6 = 0.0855 \\
&K_7 = 0.0369, K_8 = 0.0327, K_9 = 0.1152 \\
&K_{10} = 0.1705, K_{11} = 0.1418, K_{12} = 0.0708, K_{13} = 0.0544.
\end{aligned} \tag{11}$$

The values of K_1-K_{14} establish the essential turn numbers of the autotransformer windings to have the required output voltages and phase shifts. The kilovoltampere rating of the autotransformer is calculated as [4]:

$$kVA = 0.5 \sum V_{winding} \; I_{winding} \tag{12}$$

Where, $V_{winding}$ is the voltage across each autotransformer winding and $I_{winding}$ indicates the full load current of the winding. Apparent power rating of the interphase transformer is also calculated in a same way.

III. MATLAB-BASED SIMULATION

Fig. 4 shows the implemented ac-dc converter with DTCIMD in MATLAB software using SIMULINK and power system block set (PSB) toolboxes. In this model, a three-phase 460 V and 60 Hz network is utilized as the supply for the 28-pulse converter. Multi-winding transformer block is also used to model IPT.

At the converter output, a series inductance (L) and a parallel capacitor (C) as the dc link are connected to IGBT-based Voltage Source Inverter (VSI). VSI drives a squirrel cage induction motor employing vector-control strategy. The simulated motor is 50 hp (37.3 kW), 4-pole, and Y-connected. Detailed data of motor are listed in Appendix A. Simulation results are depicted in Figs. 6-15. Power quality parameters are also listed in Table I for 6-pulse, and 28-pulse ac-dc converters.

IV. RESULTS AND DISCUSSION

Table I lists the power quality indices obtained from the simulation results of the 6-pulse, and 28-pulse converters. Matlab block diagram of 28-pulse ac–dc converter system simulation, as shown in Fig. 5. Fig. 6 depicts two groups of seven-phase voltage waveforms with a phase shift of 12.86 degrees between the same voltages of each group.



Fig. 4. Matlab model of 28-pulse ac–dc converter fed DTCIMD.



Fig. 5. Matlab block diagram of 28-pulse ac–dc converter system simulation.



Fig. 6. Autotransformer output voltage.



Fig. 7. 28-pulse ac–dc converter output voltage.



Fig. 8. Waveforms depicting dynamic response of 28-pulse diode rectifier fed DTCIMD with load perturbation (source current i_{sA}, speed ω_r, developed electromagnetic torque T_e, and dc-link voltage V_{dc}).



Fig. 9. Waveforms depicting dynamic response of six-pulse diode rectifier fed DTCIMD with load perturbation.

TABLE II. COMPARISON OF POWER QUALITY PARAMETERS OF THE SIMULATED DTCIMD FED FROM DIFFERENT AC–DC CONVERTERS

Topology	% THD of V_{ac}	AC Mains Current I_{SA} (A)		% THD of I_{SA}, at		DF		DPF		TPF		DC Voltage	
		Light Load	Full Load	Light Load	Full Load	Light Load	Full Load	Light Load	Full Load	Light Load	Full Load	Light Load	Full Load
6-pulse	*5.63*	*10.25*	*52.56*	*52.80*	*28.52*	*0.884*	*0.959*	*0.985*	*0.988*	*0.872*	*0.948*	*616.6*	*607.6*
28-pulse	*2.75*	*10.61*	*52.28*	*5.08*	*3.78*	*0.998*	*0.998*	*0.998*	*0.997*	*0.997*	*0.996*	*612.7*	*609.1*



Fig. 10. Input current waveform of six-pulse ac–dc converter at light load and its harmonic spectrum.



Fig. 11. Input current waveform of six-pulse ac–dc converter at full load and its harmonic spectrum



Fig. 12. Input current waveform of 28-pulse ac–dc converter at light load and its harmonic spectrum.



Fig. 13. Input current waveform of 28-pulse ac–dc converter at full load and its harmonic spectrum.



Fig. 14. Variation of THD with load on DTCIMD in 6-pulse, and 28-pulse ac-dc converter.



Fig. 15. Variation of power factor with load on DTCIMD in 6-pulse, and 28-pulse ac-dc converter.

The 28-pulse converter output voltage (shown in Fig. 7) is almost smooth and free of ripples and its average value is 609.8 volts which is approximately equal to the DC link voltage of a six-pulse rectifier (607.6 volts). This makes the 28-pulse converter suitable for retrofit applications.

Different output and input characteristics of the proposed 28-pulse converter feeding DTCIMD such as supply current, rotor speed, electromagnetic torque, and DC link voltage are shown in Fig. 8. These waveforms can be compared with their equivalent parameters of a six-pulse fed DTCIMD that are shown in Fig. 9. The dynamic characteristics of the two converters can be used to compare their dynamic response through conditions such as starting or load variations.

Input current waveforms and its harmonic spectrum of the 6-pulse, and 28-pulse converters extracted and shown in Figs. 10-13, respectively to check their consistency with the limitations of the IEEE standard 519.

In general, the largely improved performance of the 28-pulse converter makes the power quality indices such as THD of supply current and voltage (THDi and THDv), displacement power factor (DPF), distortion factor (DF), and power factor (PF) satisfactory for different loading conditions. The aforementioned criteria are listed in Table I for the three types of converters. As mentioned previously, the required magnetic ratings of the proposed topology is 45.63% of the load rating while $THD_i < 5\%$ is achieved.

Input current THD and power factor variations are also shown in Figs. 14 and 15 respectively, for 6-pulse, and 28-pulse ac-dc converters. Results show that the input current corresponding to the proposed configuration has an almost unity power factor. Furthermore, in the worst case (light loads) the current THD has reached below 5% for the proposed topology.

V. CONCLUSION

A Polygon-Connected autotransformer was designed and modeled to make a 28-pulse ac-dc converter with DTCIMD load. Afterwards, the proposed design procedure was modified for retrofit applications. Simulation results prove that, for the proposed topology, input current distortion factor is in a good agreement with IEEE 519 requirements. Current THD is less than 5% for varying loads. It was also observed that the input power factor is close to unity resulting in reduced input current for DTCIMD load. In brief, power quality improvement of the supply current and reduced ratings of the transformers and consequently reduced cost of converter are the major benefits of the proposed 28-pulse ac-dc converter.

APPENDIX

A. *Motor and Controller Specifications*

Three-phase squirrel cage induction motor—50 hp (37.3 kW), three phase, four pole, Y-connected, 460 V, 60 Hz. R_s = 0.0148 Ω; R_r = 0.0092 Ω; X_{ls} = 1.14Ω; X_{lr} = 1.14 Ω, X_{Lm} = 3.94 Ω, J = 3.1 Kg · m^2 .

Controller parameters: PI controller Kp = 300; Ki = 2000.

DC link parameters: L_d = 2 mH; C_d = 3200 μF.

Source impedance: Z_s = j0.1884 Ω (=3%).

REFERENCES

[1] B. K. Bose, Modern Power Electronics and AC Drives. Singapore: Pearson Education, 1998.

[2] IEEE Standard 519-1992, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems. NewYork: IEEE Inc., 1992.

[3] IEC Standard 61000-3-2:2004, Limits for harmonic current emissions, International Electromechanical Commission. Geneva, 2004.

[4] D. A. Paice, Power Electronic Converter Harmonics: Multipulse Methods for Clean Power. New York: IEEE Press, 1996.

[5] R. Hammond, L. Johnson, A. Shimp, and D. Harder, "Magnetic solutions to line current harmonic reduction," in Proc. Conf. Power Con.-1994, pp. 354–364.

[6] L. J. Johnson and R. E. Hammond, "Main and auxiliary transformer rectifier system for minimizing line harmonics," U.S. Patent 5 063 487, Nov. 1991.

[7] B. Singh, S. Gairola, A. Chandra, and K. Haddad, "Multipulse AC–DC Converters for Improving Power Quality : A Review" IEEE Transactions on Power Electronics , vol. 23, no. 1, January 2008.

[8] B. Singh, G. Bhuvaneswari, and V. Garg, "Harmonic mitigation using12-pulse ac–dc converter in vector-controlled induction motor drives," IEEE Trans. Power Delivery, vol. 21, no. 3, pp. 1483–1492, Jul. 2006.

[9] F. J. Chivite-Zabalza, A. J. Forsyth, and D. R. Trainer, “Analysis and practical evaluation of an 18-pulse rectifier for aerospace applications,” Proc. 2nd Int. Conf. Power Electron. Mach.Drives (PEMD), vol. 1, pp. 338–343, 2004.

[10] G. R. Kamath, D. Benson, and R. Wood, “A novel autotransformer based 18-pulse rectifier circuit,” in Proc. 2001 IEEE IECON, Conf., 2002, pp. 795–801.

[11] B. Singh, G. Bhuvaneswari, and V. Garg, “Harmonic Mitigation in AC–DC Converters for Vector Controlled Induction Motor Drives” IEEE Transactions on Energy Conversion , Vol. 22, no. 3, pp. 637 - 646 , Sept. 2007.

[12] B. Singh, G. Bhuvaneswari, and V. Garg, “A Novel Polygon Based 18-Pulse AC–DC Converter for Vector Controlled Induction Motor Drives” IEEE Transactions on Power Electronics, vol. 22, no. 2, March 2007.

[13] B. Singh, V. Garg, and G. Bhuvaneswari , “A Novel T-Connected Autotransformer-Based 18-Pulse AC–DC Converter for Harmonic Mitigation in Adjustable-Speed Induction-Motor Drives” IEEE Transactions on Industrial Electronics , vol. 54, no. 5, October 2007.

[14] B. Singh, G. Bhuvaneswari and V. Garg, “Eighteen-Pulse AC-DC Converter for Harmonic Mitigation in Vector Controlled Induction Motor Drives”, in Proc. Int. Conf. on Power Electronics and Drives systems, 28 Oct.-01 Nov. 2005, Vol. 2, pp.1514 – 1519.

[15] B. Singh, G. Bhuvaneswari and V. Garg, “Nine-Phase AC-DC Converter for Vector Controlled Induction Motor Drives”, in Proc. IEEE Annual Conf. INDICON’05, 11-13 Dec. 2005, pp. 137–142.

[16] R. Hammond, L. Johnson, A. Shimp, and D. Harder, “Magnetic solutions to line current harmonic reduction,” in Proc. Conf. Power Con.-1994, pp. 354–364.

[17] B. Singh, G. Bhuvaneswari, V. Garg, and S. Gairola, “Pulse multiplication in ac–dc converters for harmonic mitigation in vector controlled induction motor drives,” IEEE Trans. Energy Conv., vol. 21, no. 2, pp.342–352, Jun. 2006.

[18] B. Singh, V. Garg, and G. Bhuvaneswari , “Polygon-Connected Autotransformer-Based 24-Pulse AC–DC Converter for Vector-Controlled Induction-Motor Drives” IEEE Transactions on Industrial Electronics , vol. 55, no. 1, pp.197–208, January 2008.

[19] [20] B. Singh, G. Bhuvaneswari, and V. Garg, “Power-quality improvements in vector-controlled induction motor drive employing pulse multiplication in ac–dc converters,” IEEE Trans. on Power Delivery, vol. 21, no. 3, pp. 1578–1586, Jul. 2006.

[20] B. Singh, G. Bhuvaneswari, and V. Garg, “Reduced rating T-connected autotransformer for converting three phase ac voltages to nine/six phase shifted ac voltages,” U.S. Patent 7 375 996 B2, May 2008.

[21] B. Singh, G. Bhuvaneswari, and V. Garg, “T-Connected Autotransformer-Based 24-Pulse AC–DC Converter for Variable Frequency Induction Motor Drives” IEEE Transactions on Energy Conversion , Vol. 21, no. 3, pp. 663- 672 , Sept. 2006.